

**Town of Hanover DPW  
Building Operations Group  
Open Work Order Report  
Hanover Fire Headquarters**

Printed on: 05/19/2013

Page: 1

WO #	Area Description Area Number Description of Problem	Priority Status	Requested Date	Days Aged
4315	Duct work throughout Would it be possible to have the ductwork cleaned. It has never been done and the building is 25 years old. Thanks! Time Available: M-F 8 to 4	Medium Work In Progress	08/30/2012	262
4964	3 Entry Doors Need a quote for the cost of installing 3 card-swipe (or key fob swipe) locks installed on 3 entry doors at H.Q. Time Available: M-F days	Medium Work In Progress	12/20/2012	150
5246	1st Floor Front Entry Door Front door electric lock will not work with the remote switch located at the watchroom desk. It worked until yesterday when the lock company was here doing some programing. Dugmore and Dunkan Time Available: any	Medium Work In Progress	02/28/2013	80
5270	1st Floor Front Door Dugmore and Dunkan will need to install the additional gateway to operate the front door. Current gateway location will not communicate with front door. Time Available: anytime	Medium Work In Progress	03/05/2013	75
5346	1st Floor Garage Center garage door on rear of building. Upper right hand corner glass panel has lost its seal. Moisture inbetween glass sections. Should be a warranty issue. Door Systems Inc. 800-545-3667 Time Available: Anytime	Medium Work In Progress	03/18/2013	62
5383	1st Floor Garage Weather Stripping on front, center garage door is falling off. Time Available: Anytime	Medium Work In Progress	03/25/2013	55
5603	2nd Floor Garage Urinal in second floor bathroom - continues to run after flushing. Time Available: anytime	Medium Work In Progress	05/16/2013	3

End of report: 1 pages